



Laboratorium Techniki Budowlanej Sp. z o.o.

41-306 Dąbrowa Górnicza, ul. Laski 83 ; NIP tax ID 629-246-59-43 Notified
Body/NB 1827 Accredited Body AB661
tel/fax (+48) 32 264 079; LTB@LTB.org.pl
KRS no. 0000447876; REGON no. 243166560
Share capital: PLN 66,000 District Court Katowice-Wschód, 8th
Commercial Department of the National Court Register; Share capital paid in full



AB 661

TYPE TEST (TT) CERTIFICATE

to PN-EN 13241:2003+A2:2016-10
No. 207/B-2019/2-1(A)

Laboratorium Techniki Budowlanej tested a sample of the roll-up, shutter door described in the tests register
with ref. 207/B-2019/1 and 207/B-2019/2 provided by the company:

POLFENDO

Sp. z o.o.

41-409 Mysłówice, ul. Hutnicza 10

Test object: Sample no. 207		Characteristic	Result of conformity assessment Classification standard	Conformity assessment: test standard/test result
Roller garage door		4.4.2 PN-EN 13241-1+A1:2012	PN-EN 12425:2002	PN-EN 12489:2002
		Resistance to water penetration	Class 3	At a differential pressure of 50 Pa No leakage
S= 4000 mm x W= 2500 mm		4.4.3 PN-EN 13241-1+A1:2012	PN-EN 12424:2002	PN-EN 12444:2002
Mounting opening area Ld= 10 m ²		Resistance to wind load	Class 4	Positive test pressure (+) P1 1000 Pa Safety test (+) P2 1250 Pa No damage
system: Polfendo Intense		4.4.6 PN-EN 13241-1+A1:2012	PN-EN 12426:2002	PN-EN 12427:2002
Leaf profile	AG/77	Air permeability	Class 1	Permeability at positive pressure 50 Pa 12.32 m³/(m² · h)
Side guide	Final 30082 with gaskets			[reference air permeability at 50 Pa: 24 > (Ld) ≥ 12 m ³ /(m ² · h)]
Bottom strip	11195			
Bottom seal	door02			
Reinforcing profile	omega			
Guides	Areta 77			
Guide roller	RSP77			
Leaf stabiliser	windON			
Replacement component identifiers are provided in test report 207/B-2019/2				
Declaring parameters for other objects should follow the rules provided in PN-EN 13241-1+A1:2012 Test results refer to the tested sample and test conditions				

Quality Manager

Maciej Żyła

Technical Manager

mgr inż. Bogdan Wójtowicz

Update of the reference document
Dąbrowa Górnicza, 03/12/2019